


Kristin Alexander

From: Jim Deming [jim@actonh2o.com]
Sent: Monday, February 13, 2006 9:19 AM
To: rjh@stamskiandmcnary.com
Cc: Kristin Alexander
Subject: RE: 68 Willow Street Residential Compound



Rich,

I typically don't comment on this type of "sub division", sorry if that caused any problems. The AWD will provide water supply to the proposed new dwelling on Lot #2 with a new service line specifically for that property. That line will have to come up the proposed ROW. As you say, the size of the line will be determined by the applicant. The friction loss over that distance is significant and an adequately sized line will be important to insure the owner has sufficient volume and pressure to service whatever demand is anticipated.

jim

-----Original Message-----

From: rjh@stamskiandmcnary.com [mailto:rjh@stamskiandmcnary.com]
Sent: Friday, February 10, 2006 1:56 PM
To: Jim Deming
Cc: kalexander@acton-ma.gov
Subject: 68 Willow Street Residential Compound

Jim,

We have a definitive subdivision hearing this Tuesday, Feb. 14th for a Residential Compound at 68 Willow Street. Kristin has informed us that they have not received review comments from the Water District.

Attached is a copy of the Site Development Plan. The existing dwelling #68 will maintain its current water service.

The proposed dwelling #66 is to be served by an individual private service connection from Willow Street (L=420'+). It is our understanding that the diameter of the service connection is to be determined by applicant at time of water service application.

Thank you